| | | | MINI SPLIT HEAT PU | |
|---|---------------|----------------|--------------------|----------------|
| EQUIPMENT No. | MC-HPU-1 | MC-HPU-2 | SC-HPU-1 | SC-HPU-2 |
| BUILDING | MAIN CAC | MAIN CAC | SERVICE CAC | SERVICE CAC |
| LOCATION | GUARD BOOTH | LOBBY | GUARD BOOTH | LOBBY |
| UNIT CONFIGURATION | CASSETTE | FAN COIL | CASSETTE | FAN COIL |
| INDOOR UNIT | | | | |
| SUPPLY FAN AIRFLOW, LOW/MEDIUM/HIGH (L/S) | 111/166/188 | 611/638/666 | 111/166/188 | 516/541/575 |
| OUTSIDE AIR FLOW (L/S) | 20 | 40 | 20 | 40 |
| ESP (Pa) | | 70 | | 70 |
| COOLING DATA | | | | |
| EAT (deg C db) | 29. 4 | 29. 4 | 29. 4 | 29. 4 |
| EAT (deg C wb) | 17. 8 | 17.8 | 17.8 | 17.8 |
| TOTAL COOLING CAPACITY (KW) | 3. 7 | 14. 1 | 3. 7 | 10.6 |
| COMPRESSOR HEATING DATA | | | | |
| DESIGN OA TEMP (deg C db) | 8. 9 | 8.9 | 8. 9 | 8. 9 |
| HEATING CAPACITY (KW) | 4. 0 | 15. 5 | 4. 0 | 11.7 |
| OUTDOOR UNIT | | | | |
| LOCATION | ROOF | ROOF | ROOF | ROOF |
| EAT (deg C db) | 31. 1 | 31. 1 | 31. 1 | 31. 1 |
| EAT (deg C wb) | 23. 3 | 23. 3 | 23. 3 | 23. 3 |
| SYSTEM ELECTRICAL CHARACTERISTICS | | | | |
| POWER INPUT, HEATING/COOLING (KW) | 1. 2/1. 16 | 4. 14/4. 25 | 1. 2/1. 16 | 3. 12/3. 26 |
| SYSTEM RUNNING CURRENT, HEATING/COOLING (A) | 6.8/5.3 | 11/11 | 6.8/5.3 | 8/9 |
| VOLTS | 230 | 230 | 230 | 230 |
| PHASE | 1 | 1 | 1 | 1 |
| HERTZ | 50 | 50 | 50 | 50 |
| SYSTEM SELECTION BASED ON | YORK | YORK | YORK | YORK |
| INDOOR UNIT MODEL | YKKC12FS-AAR | YUKC48DU-BCR-K | YKKC12FS-AAR | YUKC36DU-BCR-K |
| OUTDOOR UNIT MODEL | YKJC12FS-AAR | YUJC48DU-BCR | YKJC12FS-AAR | YUJC36DU-BCR |
| REFRIGERANT | R410A | R410A | R410A | R410A |
| REMARKS: | 1, 2, 3, 4, 6 | 2, 3, 4, 5, 6 | 1, 2, 3, 4, 6 | 2, 3, 4, 5, 6 |

REMARKS:

- 1. SELECT UNITS FOR OPERATION 1300 METERS ABOVE SEA LEVEL.
- 2. PROVIDE REFRIGERANT PIPING SIZED AND INSTALLED IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS.
- 3. PROVIDE WITH WASHABLE, HONEYCOMB NET SYNTHETIC TYPE FILTER.
- 4. PROVIDE OUTDOOR UNIT WITH WIND GUARD.
- 5. PROVIDE WITH CONDENSATE DRAIN PUMP.
- 6. PROVIDE WITH ALL NECESSARY PIPING, APPURTENANCES, AND SUPPORT BRACKETS.

| MP | SCH | EDL | JLE |
|----|-----|-----|-----|
|----|-----|-----|-----|

| SC-HPU-3 | CC-HPU-1 | CC-HPU-2 |
|----------------|----------------|---------------|
| SERVICE CAC | CONSULAR CAC | CONSULAR CAC |
| | | |
| MAIL AREA | LOBBY | ELEC/TELECOM |
| FAN COIL | FAN COIL | HIGH WALL |
| | | |
| 611/638/666 | 516/541/575 | //236 |
| 30 | 50 | |
| 70 | 70 | |
| | | |
| 29. 4 | 29. 4 | 29. 4 |
| 17.8 | 17.8 | 17.8 |
| 14. 1 | 10.6 | 5. 3 |
| | | |
| 8.9 | 8.9 | 8.9 |
| 15. 5 | 11. 7 | 5. 6 |
| | | |
| ROOF | ROOF | ROOF |
| 31. 1 | 31. 1 | 31. 1 |
| 23. 3 | 23. 3 | 23. 3 |
| | | |
| 4. 14/4. 25 | 3. 12/3. 26 | 1.8/1.8 |
| 11/11 | 8/9 | 7.8/7.8 |
| 230 | 230 | 230 |
| 1 | 1 | 1 |
| 50 | 50 | 50 |
| YORK | YORK | YORK |
| YUKC48DU-BCR-K | YUKC36DU-BCR-K | RAKC18 |
| YUJC48DU-BCR | YUJC36DU-BCR | RAJC18 |
| R410A | R410A | R410A |
| 2, 3, 4, 5, 6 | 2, 3, 4, 5, 6 | 2, 3, 4, 5, 6 |