

TABLE 3

REQUIRED ARCHITECTURAL SPECIAL INSPECTIONS

SYSTEM or MATERIAL	INSPECTION				REMARKS
	IBC CODE REFERENCE	CODE or STANDARD REFERENCE	FREQUENCY		
			Continuous	Periodic	
SPRAYED FIRE-RESISTANT MATERIALS					
SURFACE CONDITIONS	1704.11.1	ICC EVALUATION REPORT		X	SPECIAL INSPECTIONS APPLY TO CLEANLINESS OF STEEL, PRODUCT NAME AND TYPE, MATERIAL EXPIRATION DATE, AMBIENT CONDITIONS, APPLICATION PROCEDURES, AND MATERIAL THICKNESS AND DENSITY
APPLICATION	1704.11.2			X	
INTUMESCENT FIRE-RESISTIVE COATINGS					
SURFACE CONDITIONS	1704.11.1	ICC EVALUATION REPORT		X	SPECIAL INSPECTIONS APPLY TO CLEANLINESS OF STEEL, PRODUCT NAME AND TYPE, MATERIAL EXPIRATION DATE, AMBIENT CONDITIONS, APPLICATION PROCEDURES, AND MATERIAL THICKNESS
APPLICATION	1704.11.2			X	
EXTERIOR INSULATION AND FINISH SYSTEMS					
INSTALLATION	1704.12		X		
SMOKE CONTROL SYSTEMS					
INSTALLATION	1704.14			X	RECORD DEVICE LOCATION(S)